

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**

**LISTING No.** 7125-1209:163 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** System Sensor, 3825 Ohio Avenue, St. Charles IL 60174  
Contact Person: Andrej Nikolic (630) 377-6674

**DESIGN:** Models V4R2415ADA, V4R241575ADA, V4R2475ADA, V4R24110ADA, SP1R2415ADA, SP1R241575ADA, SP1R2475ADA, SP1R24110ADA, SP1W2415ADA, SP1W241575ADA, SP1W2475ADA and SP1W24110ADA, \*V4R2415ADAS, \*V4R241575ADAS, \*SP1R2415ADAS, \*SP1R241575ADAS, \*SP1W2415ADAS and \*SP1W241575ADAS speakers/strobes. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical/candela rating and UL label.

**APPROVAL:** Listed as combination speakers/strobes suitable for the hearing impaired for use with separately listed compatible fire alarm control units. For **wall mount** and **indoor** use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Manual for details.

\*Rev. 05-03-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 8, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy**

